

Adedge AD33 Arsenic Adsorption Media for Residential Point-of-Entry (POE) Systems

Q. What is the AD33 media?

The product is a dry, granular, iron oxide adsorption media. It has been designed specifically for reducing arsenic and is ideal for both drinking and process water applications.

Q. Does the product reduce both forms of naturally occurring arsenic?

Yes. Both arsenic (III) and arsenic (V) are reduced by the product up to 99%. For situations where 100% arsenic (III) is present, one may consider pre-oxidation for enhanced performance since the total capacity of the media for arsenic (V) is greater than for arsenic (III).

Q. How is the product applied for a residential application?

The media is typically employed within a standard, conventional-size cylindrical fiberglass tank with a top-mounted valve, laterals, riser and under bedding. Further sizing and use information is provided in AdEdge Technologies Product Bulletins.

Q. Does the AD33 media impart any odor, taste or extractables into the water?

No. The AD33 media meets NSF/ANSI drinking water Standard 61 which confirms the safety and quality of products in contact with drinking water.

Q. How long will the AD33 media last?

The media life is dependent on several key factors: water chemistry, usage patterns, contact time, and treatment goals. A typical 5-6 gpm design flow POE residential system treating arsenic 10-50 parts per billion (ppb), containing 2 cubic feet of AD33 media will last typically 2-4 years depending on the level of arsenic, gallons per day usage, pH and other factors. Testing of the effluent will determine the appropriate change out frequency.

Q. What do I need to know about the water chemistry before properly applying this product?

The product is intended to be prescribed only by qualified AdEdge Technologies dealers or distributors. The following analyses (at a minimum) are needed to predict performance: arsenic, pH, iron, manganese, hardness, sulfate, phosphate, and sulfides. Although a complete water profile would be ideal, these are the most important parameters for residential applications.

Q. How is the spent media disposed?

The spent media (after being exhausted with an arsenic containing water) has been tested and has passed the EPA's standard protocol for determining hazardous wastes. This test known as the TCLP test has shown that the media can be discarded as non-hazardous waste in a sanitary landfill.

Q. Must iron and manganese be removed prior to treatment with the AD33?

The product is not designed specifically for iron and manganese removal. Like most adsorption products, this product works best if iron and manganese are minimized before adsorption due to potential fouling of the adsorption bed with iron. Pretreatment for iron and manganese is recommended to 0.5 mg/l and 0.05 mg/l respectively prior to arsenic adsorption for best results. We have considerable experience with iron and manganese treatment. Contact AdEdge for suggested pretreatment options.

Q. Does the AD33 media need to be backwashed? If so, how often?

Periodic backwashing is recommended for two reasons. The media over time, can compact and preferential channels can develop causing short-circuiting. Additionally, sediment or suspended solids (if present) may accumulate in the adsorption media. To prevent excessive pressure drop or channeling, gentle backwashing to lift or fluff the bed is performed periodically. Backwashing for a residential system is typically performed twice a month at 5 gpm / square foot for 5-10 minutes. Since arsenic is chemically bound to the media, no arsenic is removed or desorbed during the backwashing cycle. The backwash water typically has very low or non-detectable levels of arsenic.

Q. Can the AD33 media be used in conjunction with an RO system or water softener?

Yes. The preferred location of the arsenic treatment is placement after the softener or RO system.

Q. Would pH adjustment ever be recommended?

The product has a very wide operating pH from 5.5 to 8.5. The media exhibits a higher capacity for arsenic with decreasing pH. Above 8.5 pH, one should consider lowering the pH for increasing the longevity of the media. Contact AdEdge for details.

Q. How do I monitor for arsenic?

Samples can be analyzed by a certified / qualified laboratory for total arsenic using several different methods for typically \$15-20 per sample. Field test kits are also available that can detect the presence of arsenic at very low levels (< 5 ppb). These tests have been used as inexpensive indicator system performance, but should be used in conjunction with actual laboratory results. More information can be provided about test kits by contacting AdEdge.

Q. How do I know if the AD33 media is working and what type of monitoring should be performed with residential systems?

Based on the potential health concerns with arsenic, a monitoring program is essential for all POE systems installed. The designated water dealer or service providers is responsible to test the system initially after installation to determine if treatment goals are being met and routinely thereafter throughout the operating life. Sampling frequency may vary depending on the site specifics and state requirements. A laboratory sample of the effluent is recommended at least quarterly to semi-annually. Media should be discarded and replaced with new media when the effluent no longer achieves the treatment goals.

Available through:

EDS Pumps & Plumbing Ltd.

23184 Fraser Hwy., Langley BC V2Z 2V2

Phone: 604-534-1115 Fax: 604-534-5522 Toll Free: 1-800-900-2220

Email: info@edspumps.com

Web Site www.edspumps.com